


Ln. M. SAPPANY PILLAI,
B.E., M.I.E., F.I.V., MICA
and Associates

CHARTERED ENGINEER-M/113880/9
GOVT. APPROVED VALUER - C1/170/1990

APPROVED BY AXIS BANK,
BANK OF BARODA, BANK OF CEYLON
CANARA BANK, CATHOLIC SYRIAN BANK,
CITY UNION BANK, COSMOS BANK,
DENA BANK (Now) BOB, FEDERAL BANK, HUDCO,
IOB, IOC, IFCI, JAMMU & KASHMIR, MSTC LTD.,
NATIONAL INSURANCE CO., PUNJAB SINDH BANK,
REPCO BANK, SIDBI, SOUTH INDIAN BANK,
UNION BANK OF INDIA, UNITED INDIA INSURANCE CO.,
YES BANK, OTHER BANKS INCOME TAX DEPT. ETC.


REGISTERED ENGINEER : RE/GR-1/19/04/097 ON 02.04.2019



**SERVICE ACROSS
THE NATION**

☎ Off : 044-28525589
Mobile : 98410-37806
: 72990 37807
E-mail : sappanypillai@yahoo.com (Per)
sappanypillai@gmail.com (Off)
GST No. : 33AAVPS9528G1Z0
Pan No. : AAVPS9528G

* Registered Valuer under IBB
Regd. No. IBB RV/05/2018/10427
* Registered as Valuer under Sec. 34AB /
Sec. 34AE of the Wealth Tax Act.
* Competent Person to issue
Stability Assesment by Chennai,
Kancheepuram, Tiruvallur & Chengleput




Regd. No.
UDYAM TN-02-0120886

Ref: Val/Admin1-F/Stability/Sri Chaitanya School/Mani/Amy-58/2023

Date: 18.05.2023

STATEMENT ACCOMPANYING FORM 'A'

1. Name or Door Number of building : **M/s.Sri Chaitanya Techno School,**
2. Location (Street No & Ward No) : **Door No.16/2, EVP Park Avenue, 2nd Street,
Iyyapanthangal, Alandur Taluk,
Kancheepuram District- Chennai-600 056.**
- Name of place, i.e. Corporation : **S.Nos.10/1B & 11/2**
Municipality, Panchyat/Panchayat,
Union/Township/Cantonment
3. Year of construction : **2017**
4. Approximate cost of construction
as per current rates : **Rs.3.30 Crores**
5. Purpose for which the building is
being used or proposed to be used. : **Educational Purpose**
6. Purpose for which the building
has either to been used. : **School**


Ln. M. SAPPANY PILLAI, B.E., F.I.V.,
Regd. Valuer - C1/170-1990
Chartered Engineer-M/113880-9
Regd. Engineer CMDA RE/GR-1/19-4-097 On:2-4-19
New No: 299/146, Peters Road,
Thousand Lights, Chennai-600 086.
Phone: 044-28525589 / 28522447

7. Details of construction of the building (particulars) of the foundation soil, specification of the various parts under

a)	Foundation	:	Pile Foundation
b)	Basement	:	Plinth Beam with Brick Masonry Wall
c)	Superstructure	:	Rcc Beam and Column & Brick Masonry Structure
d)	Floor and roof	:	R.C.C Roof and Tile Flooring
e)	Floor and roof area to be given	:	Ground + 2 Floors

8. Period for which license is required : Three years From : 01.06.2023
To : 31.05.2026

9. Number of Persons to be accommodated : About 1800 Pupils

Certified that no additions or alteration has been made to the existing building or portion of a building for which this application has been made. I under take to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also under take to obtain a fresh license if the purpose of the building for which the license was granted for the use of the building of a portion of the building originally is changed or shifted subsequently.

Dated:18.05.2023

Signature of the Owner of the building

Signature of Engineer

[Handwritten Signature]




FORM- B

Certified that the building of M/s. **Sri Chaitanya Techno School**, Situated at Door No.16/2, EVP Park Avenue, 2nd Street, Iyyapanthangal, Alandur Taluk, Kancheepuram District was inspected on 18.05.2023 mentioned in the statement below. I have satisfied myself that the building structurally sound to be used as a Public Building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards IS:895. The scope of this Stability Certificate is limited only to the structural soundness of the subject building (and no other structure in the premises) as per IS:456-1978: this does not include the eventualities caused by natural calamities like cyclone, earthquakes, high gales & storm, lightening ,floods, fire etc.,

Dated: 18.05.2023

Signature of the Engineer



FORM - C

Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 1 of 1965) Referred to in Rule 4 of the Tamil Nadu Public (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features;

1. Foundation:
 - a) Depth below ground level : About 7 Feet
 - b) Nature of soil set out in the foundation level : Weathered Rock
 - c) Pressure at foundation : About 11 Tons/Sq.m.
 - d) Probable safe bearing capacity of the statement with at foundation. : About 20 Tons/Sq.m.
2. Superstructure
 - (i) Maximum stress in the most critical section of the masonry and concrete : Masonry : Within the limits
RCC Column : Within the limits
 - (ii) Nature of masonry and concrete and its safe permissible stress : Masonry : 30.00 Tons/Sq.m
Concrete : 40 kg per Sq cm

The structural soundness of the building has been verified by me with reference to ISI loading standards 895 (latest version) and other relevant Indian Standard Code for practices and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may granted for the period From 01.06.2023 To 31.05.2026

Dated: 18.05.2023

Signature of the Engineer




FORM - E

Form of Report to be made to the competent authority by inspecting authorities or officers appointed under other act under Section 28 of the Tamil Nadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in Rule 7 of the Tamil Nadu Buildings Licensing Rule 1966,

- | | |
|---|--|
| 1. Name and designation of inspecting authority or officer appointed or having jurisdiction under any other act or law | Er.M.Sappany Pillai
B.E., M.I.E., F.I.V., MICA
Chartered Engineer - M/113880/9
Licensed Surveyor - Class IA.
New.No.299, Old.No.146,
Peters Road, Thousand Lights,
Chennai - 600 086 |
| Location of the building inspected
D.No, Street No, Name of the Place

i.e. Municipal/Corporation/Municipality/
Panchayat/Panchayat Union/
Township/Cantonment | M/s. Sri Chaitanya Techno School,
Door No.16/2, EVP Park Avenue, 2 nd Street,
Iyyapanthangal, Alandur Taluk,
Kancheepuram District.
Chennai-600 056. |
| 2. Date of Inspection | 18.05.2023 |
| 3. Purpose of which the building is used | Educational Purpose-A School |
| 4. Nature of defects noticed | Nil |
| 5. Suggestion for rectifying defects | Not Applicable |
| 6. If in a dangerous condition immediate action recommended to be taken. | Not Applicable |


Date: 18.05.2023

Signature of Inspecting Authority/
Officer appointed or having jurisdiction




GOVERNMENT OF TAMIL NADU
2014

Register No. 44



No. 44

KANCHEEPURAM SEPTEMBER 1, 2014

Avan, 17, Manimela, Thiruvallur, Tamil Nadu, 2014

1000000000

Director of Public Works

By

M. Shanmugam

1000000000

NOTIFICATION BY THE COLLECTOR

Tamil Nadu Public Building Licensing Act, 1964 (Act 176) including of panel of private practicing Engineers in Kanchipuram District.

For 1000000000

ORDER

1. Mr. Dora M. Sengupta Pillai residing at No. 10, 20th Cross Road, Thousand Lights, Chennai 600 014, and a representation stating that he had been included in the panel of Private Practising Engineers in Chennai District and his name was published under Class I-A category. He has requested to include his name in the Panel of Private Practising Engineers in Kanchipuram District.

2. In a office reference dated 11.08.2014, the same has been forwarded to the Engineer-in-Chief (Buildings), Chief Engineer (Buildings), Chennai Region and Chief Engineer (General), Public Works Department, Chennai for their approval/objection in the matter.

3. In the reference 3rd cited, the Engineer-in-Chief (PWD) and Chief Engineer (General), PWD, Chennai has informed that the Board of Engineers in their 714th meeting held on 14.08.2014, have approved the proposal of the petitioner and after elaborate deliberations, has resolved and recommended in the name of Dora M. Sengupta Pillai (D.O. No. 21-21-951) his name in the panel of private practicing engineers under Class I-A category (Buildings) the cost of which exceeds Rs. 20 Lakhs as per the Chennai Municipal Administration and Water Supply (M&WS) Department, dated 17.3.2014 in Kanchipuram District.



4. Based on the recommendation of the Engineer-in-Chief, WPD and Chief Engineer (General), Public Works Department, Chennai & in his letter and copy, the above Dora M. Sengupta Pillai has been ordered for inclusion and registering in the panel of Private Practising Engineers under Class I-A category (Buildings) the cost of which exceeds Rs. 20 Lakhs as per G.O. (Ms) No. 10, Municipal Administration and Water Supply (M&WS) Department, dated 17.3.2014 in Kanchipuram District.

Kanchipuram

M. SHANMUGAM
District Collector



PHOTOS



PLATE

